


Control cabinet connection diagram ZBS-6C/KP



Air wires are properly connected when the correct wire color is inserted into the correct connector.

Nr. 1 – blue hose 12”,

Nr. 2 – red hose 12”,

Nr. 3 – yellow hose 12”

Nr. 4 – Screw that needs to be unscrewed to remove the cover and clean or replace the filter

Nr. 5 – Alarm light that will turn on when the blower fails.

If the wires are properly connected, we should observe the operation of the mammoth pumps after turning on the power.